

**Sewage Spill Report
Sewage Entered a Waterway**

Name of Municipality: City of Maysville

Date of Spill: 1-9-24 Time of Spill: 0500 to 1600

Duration of Spill: 11 hours

Amount of Spill: 14,700 gallons (If this spill was a minor spill, submit this page. If it was a major spill as defined on the second page, submit both pages.)

Describe the method used to determine amount: Visual estimation of gpm overflowing from manhole and then calculated over duration of spill. Lift Station high alarm was also used to determine timeframe of spill

Location of spill: Park Lift Station in Maysville, GA

What waterway was effected? Grove Creek

Describe what happened. What caused the spill? Is the spill ongoing? Give details of the corrective actions. Has the repair been completed? Attach pictures of before and after the repair and extra sheets if needed for description. A total of 4.75 inches of rainfall was recorded during the rain event. Due to the heavy rainfall and Inflow / Infiltration into the collection system, a manhole overflowed and the sewage entered into Grove Creek. The spill is not ongoing. The City of Maysville is continuing to look at ways to improve their sewer infrastructure.

Date you called EPD: 1-10-24

Who at EPD did you talk to? Samantha Wagner

Date you reported spill to Health Department: 1-12-24

Copy of notice to Health Department included: This report

Date notice posted at spill site: 1-12-24

Picture of notice posted: will send at later date

Spill Reported to media: 1-12-24

Copy of public notice, clipping from newspaper, etc.: Will send after it is published

Signed: Matthew Speed

Date: 1-11-24

Title: Environmental Specialist

Print Name: Matthew Speed

**Sewage Spill Report
Sewage Entered a Waterway**

Major Spill: If spill was greater than 10,000 gallons or resulted in a water quality violation or exceeded weekly average maximum permit limit for BOD or TSS by \geq 50%, do the following in addition to the already listed items:

Date of publication of public notice in largest legal organ of County: Next issue

Copy or clipping of this notice included: Will send after it is published

The stream must be monitored. Check with EPD to find out parameters and frequency.

Date stream monitoring began: 1-10-24

Send the data to EPD with your monthly monitoring report. **If there is a problem or questions with the data, let EPD know immediately.**

What drinking water intakes are there downstream within 20 miles of spill?

None

Date these facilities were notified of spill: N/A

Comments, other important things:

Signed: *Matthew Speed*

Date: 1-11-24

Title: Environmental Specialist

Print Name: Matthew Speed

Note: Do not submit this page if the spill was a minor spill. Submit both pages if the spill was a major spill.